



PUBLIC AFFAIRS
City Manager

CITY OF DURHAM

For Details Contact
Junior Mobley, Superintendent
Water & Sewer Maintenance Division
Water Management
919.560.4344
Junior.Mobley@DurhamNC.gov

News Release

For Immediate Release: November 9, 2018

City of Durham Contains Sewer Spill at 109 Wakerobin Place

DURHAM, N.C. – The City of Durham Department of Water Management reports that on November 8, 2018, approximately 6,700 gallons of wastewater overflowed from a manhole at 109 Wakerobin Place into Eno River Tributary A.

The overflow occurred at approximately 9:30 a.m. The blockage was caused by roots, which were cleared and the overflow ended at approximately 10:45 a.m. The surrounding area has been remediated and there are no immediately visible adverse environmental impacts or hazards to persons or property.

The N.C. Department of Environmental Quality Division of Water Resources was notified of the event on November 8, 2018 as required by state regulations/law. For more information, contact Junior Mobley, Superintendent of Water & Sewer Maintenance.

101 City Hall Plaza, Second Floor, Durham, NC 27701

919.560.4123

DurhamNC.gov

Follow Us @CityofDurhamNC

