



CITY OF DURHAM  
*Department of Public Works*  
101 City Hall Plaza | Durham, NC 27701  
919.560.4326 | F 919.560.4316  
  
www.durhamnc.gov

**DATE:** May 10, 2016  
**TO:** Prospective Bidders  
**SUBJECT:** Contract ST-278: Ravenstone and Stonehill Estates Paving 2016  
**ADDENDUM 4:** Answers to questions

This addendum answers the following questions received on or before 12pm, May 9, 2016:

- **There appears to be some utility poles in the areas specified for storm pipe replacements. Are the relocation of utility poles to be made incidental to the line items for storm pipes?**

No, relocation of utility poles is not included in this contract. If relocation of power poles are required later, the Engineer will make a determination on how to proceed. A change order will be discussed if necessary.

- **Why are there no line items for backfilling or backfill material for sidewalks?**

It is anticipated that sidewalk construction is required only wherever the sidewalk panels have to be removed for storm pipe replacement work. So any backfilling in these areas will be covered under the respective line items for backfilling and materials for storm pipe replacements.

This addendum, as well as other details specific to the project, is available on the Public Works' project website.

<http://durhamnc.gov/592/2016-Ravenstone-Stonehill-Estates-ST-27>

Please acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

Sincerely,

Kitty M. Thomas  
Project Manager  
919-560-4326 ext. 30218  
[Kitty.Thomas@durhamnc.gov](mailto:Kitty.Thomas@durhamnc.gov)