



**NOTES:**

1. Clean potable-water hose only. Size and number of taps per TABLE 3 of AWWA C651. This hose must be removed during the hydrostatic pressure test
2. This detail applies to pipes with diameters 4 inch through 12 inches. Larger sizes must be handled on a case-by-case basis and approved by City Engineer.
3. Hydrant Meter available from City of Durham in accordance with policy.
4. No backflow permit is required for these.

DURHAM



1 8 6 9  
CITY OF MEDICINE

Dept. of Water Management  
1600 Mist Lake Dr.  
Durham, N.C. 27704

**City of Durham, NC**

USE WITH THE STANDARD SPECIFICATIONS ONLY

Voice (919) 560-4381

www.durhamnc.gov

**SUGGESTED TEMPORARY  
FLUSHING / TESTING CONNECTION**

SCALE:  
Not To Scale

DETAIL #  
2519.01

REVISION DATE:  
Feb., 2017

SHEET #:  
1 of 1