

DURHAM



1869
CITY OF MEDICINE

CITY OF DURHAM

DEPARTMENT OF PUBLIC WORKS
101 CITY HALL PLAZA • DURHAM, NC 27701
919.560.4326 • fax 919.560.4316
www.durhamnc.gov

- Engineering
- Stormwater Services
- Street Maintenance

June 4, 2012

MEMO TO: Prospective Bidders
SUBJECT: City of Durham Contract ST-262 – 2012 Speed Humps
ADDENDUM 2: Bidder Questions

This Addendum answers several questions submitted by potential bidders.

Questions:

1. What type of block is to be used?
 - a. Page 153 of the Project Manual stated that the masonry block shall be NCDOT approved 4" x 8" x 16" solid masonry block and have a nominal height of 3 5/8" and have a minimum strength of 3000 psi.
2. Are the speed humps to be striped? If so can you supply a detail?
 - a. City forces will re-stripe the street.
3. What are the widths of the speed humps?
 - a. Per the provided detail the speed hump will cover the road from the edge of pavement to the edge of pavement. The total width of speed humps to be installed, project wide, is 343 LF. The project manual locates each proposed speed hump. Potential bidders are encouraged to visit the locations and familiarize themselves with sites.

Sincerely,

Eric Halstead, PE
Project Manager