



September 29, 2020

To: Prospective Bidders

Subject: Addendum One: Schedule Change for Bid Opening, Revised Construction Drawings, and Answers to Questions.

Project: Petition Streets 2021 (ST-286)

This Addendum corrects the following for the subject referenced contract.

- **Schedule change for Bid Opening**
The Bid Opening is re-scheduled as follows:

Date/Time	Location
Tuesday, October 6, 2020, 2:00 PM	Virtual Zoom Meeting

This change supersedes all previously posted changes for bid opening date and time. All bid opening procedures remain the same.

- **Revised Construction Drawings**
The construction drawings have been revised to address discrepancies and are posted in the project website.
<https://durhamnc.gov/4256/2021-Petition-Streets-ST-286>

- **Answers to questions**

Q: Who is funding this project?

A: This is a city funded project.

Q: Can you specify which items are to follow North Carolina Department of Transportation (NCDOT) specifications or City specifications?

A: With the exception of water and sewer items, all construction is to be built to NCDOT specifications.

Q: Are water line and sanitary fittings incidental to the pipe line item? If not, can you add an item for fittings?

A: All water and sewer lines are to be paid per NCDOT quantification.

Q: Are the new Aggregate Base Course (ABC) drives paid for by the ABC Item?

A: Drawings have been revised. There are no ABC Driveways. All driveways are to be constructed with concrete.

Q: Can you add silt fence and concrete washout items to the bid form?

A: No, these items will be incidental.

Q: Is the ABC stone under the curb incidental to the curb items?

A: Yes.

Q: Can you add a typical detail for the gravel drives and the asphalt drives?

A: Gravel and asphalt driveways have been removed from the plans.

Q: Is all driveway demo part of the lump sum grading item?

A: Yes.

Q: Where does the new 48" high chain link fence get set?

A: The fencing is located on Leonard Dr. The line style has been modified in the construction drawings to be more apparent.

Q: What materials are incidental to the fire hydrant item?

A: See NCDOT Specifications Section 1515-4. All items related to hydrant are incidental.

Q: Is the MH#1 sanitary sewer on Omah St. a doghouse manhole?

A: Yes.

Q: Can all the sanitary and water services be open cut through the existing road?

A: Yes. All the streets are city maintained streets. Cuts to roads that are not being built will need to be patched using current departmental methodology subject to review.

Q: Storm Structures 27ea, looks like there is no item for the storm manholes the GI, YI & CB add up to 27 each, but there are storm manholes are not accounted for.

A: Manholes are listed the same regardless of use.

Q: Are the quantities correct on the unit price bid sheet?

A: The unit price bid sheet is no longer accurate. A following addendum will include the updated unit price bid sheet.

Please let me know if you have any questions.

Sincerely,

Erik Adkins

Project Manager

919-560-4326 ext. 30266

Erik.Adkins@durhamnc.gov