



November 29, 2021

**To:** Prospective Bidders  
**Subject:** Addendum TWO: Answers to Questions and Clarifications  
**Project:** ST-320 Repairs and Repaving 2022

**This addendum is to answer additional questions:**

**Question:** Please direct me to the specification that relates to Bid Item 19 – Pavement Edge Repair as it isn't mentioned within the project.

**Answer:** Pavement Edge Repair is Asphalt Patching but only along the edge of pavement. It is intended to be 2'-0" wide by 6" deep; B25.0C. This item quantity correlates to strip paved streets that are less than 18' wide. Where conditions permit, the 2'-0" wide milling and paving operation could extend outside the existing edge of pavement on 1 or both sides to widen the street. Pavement Edge Repair will pave back flush with the top of adjacent road structure prior to paving final surface lift. For bid pricing, this operation should be considered independent from other milling and paving operations. Removal of material and Asphalt Binder for Plant Mix are incidental.

Thank you for your interest in this project.

Sincerely,

Ana E. Jaramillo, P.E.  
Principal Engineer  
Contracting Division, Public Works  
City of Durham